

Declaration of Conformity

The mechanical Compound watermeters type MeiTwin with RPD by-pass meter manufactured by:

Sensus GmbH Hannover
Meineckestr. 10
D-30880 Laatzen

in the sense of the ATEX directive 94/9/EG article 1 (3) a do not generate, transmit, store, measure or control energy or convert it.

Herewith we declare that the mentioned mechanical Compound watermeters are not affected by the ATEX directive because of a. m. reason and do not have to pass a conformity assessment procedure acc. to this directive. The meters do not have and are not allowed to be signed acc. to the ATEX directive.

The mechanical Compound watermeters type MeiTwin with RPD by-pass meter have been tested acc. to the applicable standard EN 13463-1. They are classified under the condition of intended use in hazardous areas requiring operation facilities of:


Group I

Group II, category 2G, Gas group IIA and IIB

The intended use of the devices is the measurement of cold and hot water. They do not contain an ignition source and therefore do not form a potential explosion hazard.

For the use in hazardous areas we explicit refer to the amendment to the manual MB 9210.

Sensus GmbH Hannover

A handwritten signature in black ink, appearing to read "H. Tiemann".

Harald Tiemann

Laatzen 14.12.2009